

GENERAL NOTES:

- ALL EQUIPMENT AND WORK SHALL CONFORM WITH THE NATIONAL ELECTRICAL SAFETY CODE AND APPLICABLE UNDERWRITERS' AND GOVERNMENTAL BUILDING CODES. CERTAIN ITEMS ARE SUBJECT TO INSPECTION AND APPROVAL BY THE DUQUESNE LIGHT COMPANY.
- PRIOR TO REQUESTING SECTIONALIZING ENCLOSURE INSTALLATION, AN UNOBSTRUCTED ACCESS WAY CAPABLE OF HS20-44 (32,000 POUNDS PER AXLE) TRUCK LOADING SHALL BE PROVIDED AND PERMANENTLY MAINTAINED BY THE CUSTOMER.
- DUQUESNE LIGHT COMPANY IS TO HAVE THE RIGHT OF INGRESS AND EGRESS AT ALL TIMES. DLCO SHALL BE ABSOLVED FROM ALL PROPERTY DAMAGES DUE TO NON-NEGLIGENT INGRESS OR EGRESS OF DLCO PERSONNEL OR EQUIPMENT.

CUSTOMER WORK:

- ① INSTALL AT THE PAD, SECTIONALIZING PIT AND/OR POLE, 90° ELBOWS. THE ELBOWS SHOULD BE PVC SCHEDULE 80, TYPE DB, IN ACCORDANCE WITH NEMA SPECIFICATION TC2. THE USE OF PVC ELBOWS WILL NOT REQUIRE THE USE OF GROUNDING BUSHINGS.

EXTEND BENDS " INTO PAD OR SECTIONALIZING PIT OPENING OR 6" UP POLE. DRILL (4) 1/2" DIA. HOLES ON 2" CENTERS AT THE LOW POINT OF EACH BEND AND REMOVE ALL INTERNAL BURRS. INSTALL AN 18"x18"x24"D FRENCH DRAIN. INSTALL A 18" GAUGE PULL CORD WITH A MINIMUM BREAKING STRENGTH OF 1800 POUND IN EACH CONDUIT. TO PROVIDE ALL TRENCHING, BACKFILLING, AND SURFACE RESTORATION. NO BACKFILLING SHALL BEGIN UNTIL THE PRIMARY ELECTRICAL CONDUIT HAS BEEN INSPECTED AND APPROVED BY DUQUESNE LIGHT COMPANY.
- ② CUSTOMER TO EXCAVATE PIT FOR SECTIONALIZING ENCLOSURE AS SHOWN. ENCLOSURE TO BE A MINIMUM OF 5' FROM VEHICULAR TRAFFIC AND HAVE 9'x9' CLEAR, LEVEL, UNOBSTRUCTED WORK AREA AT FRONT OF ENCLOSURE.
- ③ THE EXCAVATION SHALL HAVE A FINAL INSPECTION BY DUQUESNE LIGHT CO. PRIOR TO THE INSTALLATION OF THE SECTIONALIZING ENCLOSURE. (412-393-4343).

GENERAL NOTES/CUSTOMER WORK