



NOTES:

1. WHEN NO SIDEWALKS ARE PLANNED, DLCO EQUIPMENT SHALL BE LOCATED NO CLOSER THAN 5' FROM BACK OF CURB AND WITHIN ROAD RIGHT OF WAY.
2. IF SIDEWALKS ARE PLANNED, DLCO EQUIPMENT IS TO BE LOCATED NO FURTHER THAN 15' FROM THE FACE OF THE CURB TO FACE OF EQUIPMENT, WHICH MAY REQUIRE DLCO FACILITIES WITHIN THE 10' UTILITY EASEMENT.
3. ALL TRENCHES ARE TO MAINTAIN THE SAME DISTANCE FROM THE FACE OF DLCO EQUIPMENT THROUGHOUT THE DEVELOPMENT, AND TO BE AS STRAIGHT AS POSSIBLE. THE CENTERLINE OF TRENCHES FOR DLCO CABLES SHALL BE NO FURTHER THAN 2" FROM THE FACE OF EQUIPMENT.
4. DISTANCES VARY ACCORDING TO MUNICIPALITY REQUIREMENTS.
5. MAINTAIN A MINIMUM OF 3' HORIZONTAL SEPARATION FROM OTHER UTILITIES NOT IN SAME TRENCH, SUCH AS GAS & SEWAGE UNLESS MUNICIPAL ORDINANCE STIPULATES OTHERWISE.
6. DLCO FACILITIES SHALL NOT BE LOCATED UNDER SIDEWALKS.
7. NO TREES, SHRUBS, ETC., SHALL BE PLANTED WITHIN 6' OF EDGES OF TRENCHES FOR DLCO CABLES.

TYPICAL DLCO EQUIPMENT ROAD PROFILE
NTS